

BUILDING SAFETY CERTIFICATE

No. CEB/MECH/10/2017/158

Dated: 28/03/2024.

Certified that the existing building Holy Child School, Guwahati (name of the building or premises) at Rishma Nagar, Chandmari, Guwahati-5 (Assam) (address) comprised of 2 Blocks of basement(s) and Ground, First & Second Floor (upper floors) owned/occupied by Holy Child School, Rishma Nagar, Chandmari, Guwahati-3 (Assam) (name of the Institution) have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of PWD (Building), Assam (Name of Department/ Govt.) on 16/03/24 (date of inspection) in the presence of Vice Principal Sr. Rebecca Hajiwary (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy upto classes Up to XII (XI XII) with effect from 28/3/24 for a period of 2 (Two) years in accordance with rule and subject to compliance of the specific conditions as appended.

1. Ceiling Height measured from Floor is 12'. Cantilever Width is 8'9".
2. Staircase Width is 5'2", Rise of Step is 5.2" & Tread is 6".
3. Fire Safety Measures like Hydrant, Sand bucket, Alarm System
4. Hose Reels are installed in all the Floors. There is ample space for Fire Tenders to move freely in case of Emergency.

Issued on 28th Mar, 2024 at 1430 hrs by

* Strike out whichever is not applicable.

28/03/24
Assistant Executive Engineer (TS-VIII)

Signature with Seal: Of the Chief Engineer, PWD (Bldg), Assam, Chandmari, Guwahati-3

Name: Ashlesha Kalman, AEE

Designation: Asst. Executive Engineer

Name & Address of Department/ Office: 90 The CE (Bldg), Assam, Chandmari, City-3

(Assistant Engineer & above officer of concerned Govt. Department only)

Note: This certificate should be signed / issued by Assistant Engineer & above officer of concerned Govt. Department only

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Attended

28/03/24
Holy Child School
Guwahati-781003